

**DIRECT TESTIMONY
OF
GERRY SHEERIN, P. ENG
ON BEHALF OF
PIEDMONT ENVIRONMENTAL COUNCIL
BEFORE THE
STATE CORPORATION COMMISSION OF VIRGINIA
CASE NOS. PUE-2007-00031 AND PUE-2007-00033**

1 **Q: PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

2 A: Gerry Sheerin. Sheerin Technical, 25 Eastville Avenue, Toronto, Ontario Canada
3 M1M 2N6

4 **Q: WHAT IS YOUR PROFESSION?**

5 A: I am a qualified professional electrical engineer licensed in the Province of
6 Ontario, Canada.

7 **Q. PLEASE DESCRIBE YOUR PROFESSIONAL TRAINING AND
8 EXPERIENCE.**

9 A. My current curriculum vitae is attached hereto as Exhibit GS-1.

10 **Q. DESCRIBE ANY PROFESSIONAL ASSOCIATIONS OF WHICH YOU
11 ARE A MEMBER.**

12 A. I am a member of Professional Engineers Ontario.

13 **Q. PLEASE BRIEFLY SUMMARIZE YOUR EMPLOYMENT HISTORY
14 AND PROFESSIONAL EXPERIENCE.**

15 A. I have been employed by EHV Power for the last seven years. This has been in a
16 number of senior engineering and project management positions and ultimately Vice
17 President Projects and Engineering. EHV designs and installs high-voltage underground
18 cable systems. Previously, I was employed for twenty years by Ontario Hydro, one of the
19 largest electrical power utilities in Canada. At Ontario Hydro my responsibilities

1 included the commissioning, maintenance and repair program for a 220 mile system of
2 high-voltage underground cables. Before that I worked with Canada Wire, a high-voltage
3 cable system manufacturer for nine years.

4 **Q. WHAT DOES EHV POWER DO?**

5 A. EHV primarily is a constructor of underground high-voltage power cable systems.
6 EHV Power began operations in 1997 when the cable manufacturer Alcatel Canada Wire
7 & Cable closed its high-voltage cable manufacturing plant in Toronto, Ontario. The
8 principals of EHV Power had all been employed in the High-Voltage Cable Installation
9 Group at Alcatel. Since its formation EHV Power has been active in Canada, the US and
10 the Caribbean installing 69kV, 115kV and 230kV cables and supplying specialized
11 accessories. These activities have included all of the popular cable constructions such as
12 Solid Dielectric, High Pressure Fluid Filled and Low Pressure Fluid Filled cables. I
13 provided project management and engineering support for the company's tendering and
14 construction activities and also engineering support to customers in the area of high-
15 voltage power cable condition assessment and maintenance and repair activities.

16 **Q. PLEASE DESCRIBE YOUR RESPONSIBILITIES AND EXPERIENCE AT**
17 **EHV WITH RESPECT TO UNDERGROUND HIGH-VOLTAGE**
18 **TRANSMISSION FACILITIES.**

19 A. EHV Power is a designer and installer of high-voltage underground cable systems
20 with secondary focus on the maintenance, repair and relocation of existing high-voltage
21 cable systems. My responsibilities have included cable system design, cost estimation,
22 preparation of tender submissions, project scheduling, management of construction
23 activities and including the supervision of others involved in such activities. I also

1 conducted assessments of the condition and reliability of older high-voltage cable
2 systems for EHV's utility clients.

3 **Q. DESCRIBE ANY OTHER EXPERIENCE YOU HAVE WITH HIGH-**
4 **VOLTAGE UNDERGROUND CABLE.**

5 A. My experience in high-voltage cables includes 20 years at Ontario Hydro in
6 positions such as Cable Supervisor, Transmission Lines Superintendent and Group
7 Leader Cables. In those capacities I was actively involved in directing the maintenance-
8 and-repair programs for operating cable installations and the commissioning of new cable
9 systems.

10 **Q. HAVE YOU TESTIFIED BEFORE AS AN EXPERT WITNESS?**

11 A. Yes, once in a 2006 Virginia State Corporation Commission hearing into an
12 overhead 230 kV transmission line in Loudoun County, Virginia.

13 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THESE**
14 **PROCEEDINGS?**

15 A. Counsel for the Piedmont Environmental Council requested that I analyze the
16 feasibility of installing a power transmission cable system underground between the 502
17 Junction substation to the Loudoun substation should the Virginia State Corporation
18 Commission determine that the additional transmission line capacity for which Dominion
19 Virginia Power (DVP) and Trans-Allegheny Interstate Line Company have applied is
20 needed. The purpose of my testimony is to report on my analysis, discuss the reliability
21 of underground cable systems, and respond to certain parts of the testimony of Mr.
22 Koonce of DVP and Messrs P. Jeffrey Palermo and Richard A. Wakefield of KEMA on
23 behalf of DVP.

1 **Q. MR. SHEERIN, DOES YOUR TESTIMONY APPLY EQUALLY TO BOTH**
2 **THE PREFERRED AND ALTERNATE ROUTE?**

3 A. Yes, it does.

4 **Q. ARE YOU OFFERING ANY OPINION ON THE SUBJECT OF NEED**
5 **FOR THE ADDITIONAL TRANSMISSION CAPABILITY SOUGHT BY DVP,**
6 **OR WHETHER THERE MAY BE SUPERIOR ALTERNATIVES?**

7 A. No. Those subjects are covered in the testimonies of Drs. Hyde Merrill, Daniel
8 Violette, and Benjamin Sovacool

9 **Q. ARE HIGH VOLTAGE UNDERGROUND CABLES COMMONLY**
10 **INSTALLED IN ELECTRIC UTILITY TRANSMISSION SYSTEMS?**

11 A. Yes. There are many examples of underground power transmission throughout
12 North America, Europe, the Middle East, Africa, Asia, Australia and New Zealand.
13 Many of these cables have been in operation for decades.

14 **Q. IS IT USUAL FOR ELECTRIC UTILITIES TO INSTALL**
15 **UNDERGROUND SECTIONS IN A HIGH VOLTAGE TRANSMISSION**
16 **SYSTEM?**

17 A. Generally electric utilities prefer to install all of their transmission system
18 overhead. This provides the lowest construction costs, maintains uniform system
19 characteristics and simplifies maintenance activities over the life of the installation.
20 However, not all areas where power transmission is required are suitable for an above-
21 ground system to be constructed. In those situations electrical utilities accept the higher
22 cost and greater system complexity by installing underground cables. While initial
23 construction costs of underground cable are higher than for aboveground, operating and

1 maintenance costs can be less than for overhead systems, due in part to the higher
2 reliability of underground cables.

3 **Q. UNDER WHAT KIND OF CIRCUMSTANCES MIGHT YOU FIND**
4 **UTILITIES TURNING TO UNDERGROUND CABLES?**

5 A. The most common reason for a utility selecting underground transmission instead
6 of overhead, is a lack of available land for an overhead transmission line corridor. The
7 right of way needed for an underground cable is significantly less wide than the right of
8 way required for an equivalently sized overhead transmission line. Typically planners
9 will opt for an underground installation in built-up urban area. Other reasons might
10 include legislated restrictions on overhead construction, height restrictions adjacent to
11 airport flight paths, public opposition to the visual impact of overhead lines or to the
12 perceived public safety issue of electric and magnetic fields emanating from the lines.

13 **Q. ARE UNDERGROUND CABLES LESS RELIABLE THAN OVERHEAD**
14 **LINES?**

15 A. No, in general, high voltage underground cables are more reliable than overhead
16 transmission lines. If an underground cable is supplied by a reputable manufacturer and
17 installed by a qualified and knowledgeable contractor, the results should be outstanding
18 in terms of reliability. A properly installed underground cable should still be operating
19 reliably more than forty years after commissioning. While overhead transmission lines
20 are also reliable from a catastrophic failure viewpoint, they are prone to short term
21 failures due to extreme weather conditions, undergrowth encroachment on the space
22 surrounding the conductors and damage from construction equipment or airborne debris,
23 or even industrial pollution.

1 **Q. WHAT WAS YOUR EXPERIENCE WITH UNDERGROUND CABLES AT**
2 **ONTARIO HYDRO?**

3 A. Ontario Hydro operated over 200 miles of underground power transmission cable
4 with excellent reliability. These underground cables were installed from 1947 to the
5 present day. They included low pressure fluid filled cables, high pressure pipe type
6 cables and cross linked polyethylene cables.

7 **Q. DID YOUR EXPERIENCE WITH ONTARIO HYDRO INCLUDE ANY**
8 **INVOLVEMENT WITH OVERHEAD TRANSMISSION LINES?**

9 A. Yes.

10 **Q. WERE THESE LINES RELIABLE?**

11 A. Generally yes, as long as ongoing maintenance was satisfactory. However,
12 overhead lines are particularly vulnerable to faults caused by the encroachment of
13 neglected undergrowth and by severe weather conditions.

14 **Q. DESCRIBE, GENERALLY, THE CONSTRUCTION METHOD THAT**
15 **DVP PROPOSES FOR INSTALLATION OF AN UNDERGROUND CABLE AS**
16 **AN ALTERNATIVE TO AN OVERHEAD LINE.**

17 A. DVP proposes using single trenches, each of which would contain a pair of Direct
18 Current Solid Dielectric Cables. Each trench would be 18 inches wide and spaced 10 feet
19 apart. A separate trench would be used for each pair of cables. Each trench would be
20 filled with a low thermal resistivity backfill material (such as limestone) which would be
21 compacted to a high density. The trench would then be covered by a thick concrete slab.
22 Joint bays or manholes for cable jointing would be positioned at intervals of
23 approximately 2,000 feet. Deviations from this style of construction might occur at the

1 crossings of major highway or sensitive environmental areas. At those locations
2 horizontal directional drilling would be the most effective method of installing individual
3 conduits into which the cables could be pulled.

4 **Q. ARE YOU AWARE THAT MR. KOONCE OF DVP HAS ESTIMATED**
5 **THAT THE COST OF SUCH AN UNDERGROUND CABLE INSTALLATION**
6 **WOULD BE \$328 MILLION?**

7 A. Yes.

8 **Q. DO YOU BELIEVE THAT IS A REASONABLE ESTIMATE?**

9 A. I believe it to be at the high end of the range of likely costs. We have been
10 provided no backup work papers, independent study or other information as to how Mr.
11 Koonce made his estimate. I would be very surprised if an actual detailed estimate did not
12 produce a value at least 20% lower.

13 **Q. WHY IS THAT, MR. SHEERIN?**

14 A. Firstly because electric utilities tend to incorporate into their estimates all of the
15 worst case eventualities that may possibly occur during construction. Secondly the
16 construction of long trenches through fields on this scale can be done very efficiently at
17 lower unit costs than with shorter installations in more urban environments. Thirdly, by
18 comparing the cost per mile from the budgeted \$328 million against the cost of
19 previously installed High-Voltage cable installations. Finally, the DVP estimate is based
20 on installing three circuits while the KEMA report suggests that two parallel circuits may
21 be adequate for the required power transmission. Taken together these factors suggest to
22 me that the current cost estimates are on the high side.

1 **Q. MR. SHEERIN, ARE YOU TESTIFYING ON THE COST THAT MR.**
2 **KOONCE ESTIMATED FOR THE AC-DC CONVERTER STATIONS?**

3 A. No, I am not.

4 **Q. HOW LONG DO YOU BELIEVE IT WOULD TAKE TO CONSTRUCT A**
5 **41 MILE UNDERGROUND CABLE SECTION?**

6 A. I believe this could be constructed in about two years.

7 **Q. IN YOUR OPINION, DOES THE UNDERGROUND ALTERNATIVE OF**
8 **DVP REPRESENT A PRUDENT AND REASONABLE OPTION FOR THE**
9 **STATE CORPORATION COMMISSION TO CONSIDER REQUIRING,**
10 **SHOULD THERE BE A DETERMINATION THAT AN ADDITIONAL POWER**
11 **LINE IS NEEDED?**

12 A. Yes.

13 **Q. HAVE YOU REVIEWED THE REPORT PREPARED BY MESSRS P.**
14 **JEFFREY PALERMO AND RICHARD A. WAKEFIELD OF KEMA?**

15 A. Yes.

16 **Q. DO YOU AGREE WITH THEIR CONCLUSIONS REGARDING THE USE**
17 **OF DC UNDERGROUND CABLES?**

18 A. No, not entirely. Their conclusions appear to be heavily weighted toward
19 utilizing the lowest cost method of transmission line construction. With this limitation in
20 mind it would be very difficult for any alternative to be successful regardless of the
21 intrinsic technical or aesthetic merits that it may offer.

22 **Q. DOES THE KEMA REPORT MAKE ANY COMMENT ON THE**
23 **RELIABILITY OF UNDERGROUND HIGH-VOLTAGE CABLES?**

1 A. Not directly, the comments in this report on the underground options are very
2 cursory. There is a suggestion that the risk of cable failure is increased if the number of
3 splices is increased. This is a curious suggestion since properly installed splices, made
4 under the supervision of the cable manufacturer, have an extremely high success rate. In
5 my experience, splice or termination failures are only likely if the cables have been
6 installed by contractors who do not utilize properly qualified and experienced craftsmen
7 following the manufacturers' procedures. It is true that the contractors who follow all
8 appropriate procedures may not be the lowest bidders for a project such as this, but in the
9 long run the money saved by using the cheapest installer is quickly swamped by the cost
10 of problems experienced later. If a High-Voltage cable installation is approached as an
11 infrastructure project with an effective life expectancy of 50 or more years, then a high
12 level of installation expertise is essential. To ensure expert installation it is prudent to
13 utilize company inspectors who are themselves experienced and can truly monitor the
14 quality level of the installation of cables, splices and terminations.

15 **Q. THANK YOU, MR. SHEERIN, NO FURTHER QUESTIONS.**